



4" W.G. Flat Oval Construction For 8" Minor

Stock Diameter	Order Size	Equivalent Round	Spiral Seam Gauge	Fitting Gauge	<u>M/F Joint</u>	Reinforcement Max. Spacing
					*Optional Tie Rod for Easy Install	
18Ø	24x8	14.39Ø	22ga	20ga	N/R	D @ 8'
20Ø	27x8	15.19Ø	22ga	20ga	N/R	E @ 6'
22Ø	30x8	15.92Ø	22ga	20ga	N/R	E @ 5'
24Ø	33x8	16.61Ø	22ga	20ga	N/R	F @ 5'
26Ø	37x8	17.25Ø	22ga	18ga	N/R	F @ 5'
28Ø	40x8	17.86Ø	22ga	18ga	1 - 1/2" Tie Rods	G @ 4'
30Ø	43x8	18.62Ø	22ga	18ga	1 - 1/2" Tie Rods	G @ 4'
32Ø	46x8	19.16Ø	22ga	18ga	1 - 1/2" Tie Rods	G @ 3'
34Ø	49x8	19.68Ø	22ga	18ga	1 - 1/2" Tie Rods	G @ 3'
36Ø	52x8	20.17Ø	20ga	18ga	1 - 1/2" Tie Rods	H @ 3'
38Ø	56x8	20.65Ø	20ga	18ga	1 - 1/2" Tie Rods	H @ 3'
40Ø	59x8	21.11Ø	20ga	18ga	1 - 1/2" Tie Rods	I @ 3'
42Ø	62x8	21.55Ø	20ga	16ga	1 - 1/2" Tie Rods	I @ 3'
44Ø	65x8	22.12Ø	20ga	16ga	2 - 1/2" Tie Rods	I @ 3'
46Ø	68x8	22.53Ø	20ga	16ga	2 - 1/2" Tie Rods	I @ 3'
48Ø	71x8	22.93Ø	18ga	16ga	2 - 1/2" Tie Rods	J @ 3'
50Ø	74x8	23.31Ø	18ga	16ga	2 - 1/2" Tie Rods	J @ 3'
52Ø	78x8	23.70Ø	18ga	16ga	2 - 1/2" Tie Rods	J @ 3'
54Ø	81x8	24.00Ø	18ga	16ga	2 - 1/2" Tie Rods	J @ 2.5'

*Reinforcement requires either one internal tie rod, or two external tie rods.